




TEST CERTIFICATE

SUMMARY OF TEST RESULTS

NUMBER	0315	DATE	06 /10 / 03
---------------	-------------	-------------	--------------------

Client' s data:	ALUMIL – MILONAS S.A. Industrial Area Kilkis GR 611 00 KILKIS GREECE
Product description:	SINGLE SASH DOOR OPENING / TILTING
Material:	ALUMINIUM
System :	M 11000



2190 x 870 mm

Air Permeability ELOT EN 1026:2000 / ELOT EN 12207:2000	Class 4
Watertightness ELOT EN 1027:2000 / ELOT EN 12208:2000	Class 9A
Resistance to Wind Load ELOT EN 12211:2000 / ELOT EN 12210:2000	Class C5

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.

MARIANTHI CHATZIANTONIOU
TECHNICAL MANAGER

IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL