Evidence of Performance

Energy efficiency and thermal insulation

Test report 432 29876/2e*

* Translation of Test Report 432 29876/2 dated 10 May 2005



Product

Designation

Dimensions of

cross section

ALUMIL - MILONAS ALUMINIUM INDUSTRY S. A.

Industrial Area

61100 KILKIS GREECE

t	Movable systems: sash-frame-transom combination
1	M 11500 ALUTHERM SUPER PLUS
f	Depth of frame / transom 76.5 mm
1	Depth of sash 84 mm

Variable projected width Projected width:

Material Thermal break aluminium profile, coated Surface

Fixed systems: Frame / transom

Continuous polythermide bars, Polyamide 6.6 with 25 % glass fibre slightly oxidised surfaces, e.g. cavities following surface

Type and material treatment by immersion of thermal break

Special features

Basis

ift Guideline WA-01/1 (February 2002) "Verfahren zur Ermittlung von $U_{\rm f}$ -Werten für thermisch getrennte Metallprofile aus Fenstersystemen (Determination of the $U_{\rm f}$ -values of thermal break metal profiles used in window systems)


EN ISO 10077-2: 2003-10 Calculation of thermal transmittance $U_{\rm f}$ Numerical method for frames.

Equivalent to the national versions DIN EN ISO as well as DIN FN

Test report 432 29876/2 dated 10 May 2005

Representation

see Annex 1



Thermal transmittance



 $U_{\rm f}$ = 1.9 – 2.1 W/(m² · K) *

The specified range of values refers to the profile combinations listed in tables 4 and 5 of this report. The $U_{\rm f}$ -values for additional profile combinations of the system are determined using the linear regression in accordance with table 6.



ift Rosenheim 08 May 2007

Norbert Sack, Dipl.-Phys.

Specht, Dipl.-Ing. (FF

Test Engineer

ift Centre Glass, Building Materials and Building Physics

Instructions for use

This test report serves to demonstrate the thermal transmittance U_{f} of the tested profile system.

The data and results given refer solely to the described and tested specimen.

Testing the thermal transmittance does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication

The ift Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as abstract

The report comprises a total of 12 page.

- Object
- Procedure
- Detailed results Annex 1 (4 pages)

Notified Body Nr.: 0757 Anerkannte PÜZ-Stelle: BAY 18



Head of Testing Department for building physics ift Centre Glass, Building Materials & Building **Physics**

Dipl.-Ing. (FH) Ulrich Sieberath Dr. Jochen Peichl

ift Rosenheim GmbH Geschäftsführer